



SMS LABS SERVICES PRIVATE LIMITED

TEST REPORT



Page 1 of 4

Report No : ENC-21080045-01

Report Date: 13 Aug 2021

Customer Name : M/s. A.R.Dairy Food Private Limited
Customer Address : No:10/5C, Madurai Road,Begampur Post, Dindigul-624002.
Sample Name : Water Sample Quantity : 15 Ltr
Sample Description : Potable Raw Water Sample Received on : 09 Aug 2021
Reference : Test Request Form Dated 07.08.2021 Test Started on : 09 Aug 2021
Sample Drawn By : Customer Test Completed on : 13 Aug 2021
Sample Location : UGR Main Tank A,B & C

TEST RESULTS

S.NO	Parameter	Test Method	Unit	Results	Requirements as per IS 10500-2012-Amd : 3	
					Acceptable Limit	Permissible Limit in the absence of alternative source
Biological						
1	Escherichia coli	IS 15185	Per 100mL	Absent	Absent/100mL	Absent/100mL
2	Total Coliforms	IS 15185	Per 100mL	Absent	Absent/100mL	Absent/100mL
Clause 4, Table 1 Organoleptic And Physical parameters						
3	Colour	IS 3025 (Part 04)	Hazen	2	5.0 Max	15.0 Max
4	Odour	IS 3025 (Part 05)	--	Agreeable	Agreeable	Agreeable
5	pH Value	IS 3025 (Part 11)	--	6.92	6.5 - 8.5	No Relaxation
6	Taste	IS 3025 (Part 08)	--	Agreeable	Agreeable	Agreeable
7	Total Dissolved Solids	IS 3025 (Part 16)	mg/L	68.6	500.0 Max	2000.0 Max
8	Turbidity	IS 3025 (Part 10)	NTU	0.4	1.0 Max	5.0 Max
Clause 4, Table 2 General Parameters Concerning Substances Undesirable In Excessive Amounts						
9	Aluminium	IS 3025 (Part 65)	mg/L	BLQ(LOQ:0.001)	0.03 Max	0.2 Max
10	Ammonia (as Total Ammonia-N)	IS 3025 (Part 34)	mg/L	BLQ(LOQ:0.03)	0.5 Max	No Relaxation
11	Anoinic Detergents (as MBAS)	Annex K of IS 13428	mg/L	BLQ(LOQ:0.05)	0.2 Max	1.0 Max
12	Barium	IS 3025 (Part 65)	mg/L	BLQ(LOQ:0.001)	0.7 Max	No Relaxation
13	Boron	IS 3025 (Part 65)	mg/L	BLQ(LOQ:0.001)	0.5 Max	2.4 Max

S. Anbarasan
Authorized Signatory - Biological

M. Sarathkumar
Authorized Signatory - Chemical

Laboratory Address : 39/6, Thiruvallur High Road, Puduchatram Post, Thirumazhisai Via, Poonamallee Taluk, Chennai - 600124.
Certified By : ISO 9001 & OHSAS 18001.

- ★ The results relate only to the items tested.
- ★ Reports shall not be reproduced except in full without the approval of the Laboratory.
- ★ The Laboratory's responsibility under this report is limited to proven willful negligence and will in no case be more than the invoiced amount. The Laboratory accepts no liability with regard to the origin or source from which the sample(s) is/are said to be extracted.

S.NO	Parameter	Test Method	Unit	Results	Requirements as per IS 10500-2012-Amd : 3	
					Acceptable Limit	Permissible Limit in the absence of alternative source
14	Calcium (as Ca)	IS 3025 (Part 40)	mg/L	41	75.0 Max	200.0 Max
15	Chloramines (as Cl ₂)	APHA 23rd Edition:4500 Cl G 2017	mg/L	BLQ(LOQ:1.0)	4.0 Max	No Relaxation
16	Chloride (as Cl)	IS 3025 (Part 32)	mg/L	146	250.0 Max	1000.0 Max
17	Copper	IS 3025 (Part 65)	mg/L	BLQ(LOQ:0.001)	0.05 Max	1.5 Max
18	Fluoride (as F)	IS 3025 (Part 60)	mg/L	0.3	1.0 Max	1.5 Max
19	Free Residual Chlorine	IS 3025 (Part 26)	mg/L	BLQ(LOQ:0.1)	0.2 Min	1.0 Min
20	Iron (as Fe)	IS 3025 (Part 53)	mg/L	BLQ(LOQ:0.05)	1.0 Max	No Relaxation
21	Magnesium (as Mg)	IS 3025 (Part 46)	mg/L	21	30.0 Max	100.0 Max
22	Manganese	IS 3025 (Part 65)	mg/L	BLQ(LOQ:0.001)	0.1 Max	0.3 Max
23	Mineral Oil	IS 3025 (Part 39)	mg/L	BLQ(LOQ:1.0)	1.0 Max	No Relaxation
24	Nitrate (as NO ₃)	APHA 23rd Edition:4500 NO ₃ B 2017	mg/L	7	45.0 Max	No Relaxation
25	Phenolic Compound (as C ₆ H ₅ OH)	IS 3025 (Part 43)	mg/L	BLQ(LOQ:0.001)	0.001 Max	0.002 Max
26	Selenium	IS 3025 (Part 65)	mg/L	BLQ(LOQ:0.001)	0.01 Max	No Relaxation
27	Silver	IS 3025 (Part 65)	mg/L	BLQ(LOQ:0.001)	0.1 Max	No Relaxation
28	Sulphate (as SO ₄)	IS 3025 (Part 24)	mg/L	45	200.0 Max	400.0 Max
29	Sulphide (as H ₂ S)	IS 3025 (Part 29)	mg/L	BLQ(LOQ:0.04)	0.05 Max	No Relaxation
30	Total Alkalinity (as CaCO ₃)	IS 3025 (Part 23)	mg/L	192	200.0 Max	600.0 Max
31	Total Hardness (as CaCO ₃)	IS 3025 (Part 21)	mg/L	184	200.0 Max	600.0 Max
32	Zinc	IS 3025 (Part 65)	mg/L	BLQ(LOQ:0.001)	5.0 Max	15.0 Max
Clause 4, Table 3 Parameters Concerning Toxic Substances						
33	Arsenic	IS 3025 (Part 65)	mg/L	BLQ(LOQ:0.001)	0.01 Max	No Relaxation
34	Bromo dichloromethane	SMSLA/GEF/SOP/03	mg/L	BLQ (LOQ:0.005)	0.06 Max	No relaxation
35	Bromoform	SMSLA/GEF/SOP/03	mg/L	BLQ (LOQ:0.005)	0.1 Max	No Relaxation
36	Cadmium	IS 3025 (Part 65)	mg/L	BLQ(LOQ:0.001)	0.003 Max	No Relaxation
37	Chloroform	SMSLA/GEF/SOP/03	mg/L	BLQ (LOQ:0.005)	0.2 Max	No Relaxation
38	Chromium	IS 3025 (Part 65)	mg/L	BLQ(LOQ:0.001)	0.05 Max	No Relaxation
39	Cyanide (as CN)	IS 3025 (Part 27)	mg/L	BLQ(LOQ:0.01)	0.05 Max	No Relaxation

A. Manikandan
A. Manikandan
 Authorized Signatory - Chemical

M. Sarathkumar
M. Sarathkumar
 Authorized Signatory - Chemical

Report No : ENC-21080045-01

Report Date: 13 Aug 2021

S.NO	Parameter	Test Method	Unit	Results	Requirements as per IS 10500-2012-Amd : 3	
					Acceptable Limit	Permissible Limit in the absence of alternative source
40	Dibromochloromethane	SMSLA/GEF/SOP/03	mg/L	BLQ (LOQ:0.005)	0.1 Max	No Relaxation
41	Lead	IS 3025 (Part 65)	mg/L	BLQ(LOQ:0.001)	0.01 Max	No Relaxation
42	Mercury	EPA 200.8	mg/L	BLQ(LOQ:0.0005)	0.001 Max	No Relaxation
43	Molybdenum	IS 3025 (Part 65)	mg/L	BLQ(LOQ:0.001)	0.07 Max	No Relaxation
44	Nickel	IS 3025 (Part 65)	mg/L	BLQ(LOQ:0.001)	0.02 Max	No Relaxation
45	Uranium	IS 3025 (Part 65)	mg/L	BLQ(LOQ:0.001)	0.03 Max	No Relaxation
46	PAHs	SMSLA/GS/SOP/01	mg/L	BLQ(LOQ:0.00001)each	0.0001 Max	No Relaxation
47	PCBs	SMSLA/GS/SOP/01	mg/L	BLQ(LOQ:0.00001)each	0.0005 Max	No Relaxation
Clause 4, Table 5 Pesticide Residues						
48	2,4-D	SMSLA/LS/SOP/01	µg/L	BLQ(LOQ:0.01)	30.0 Max	No Relaxation
49	Alachlor	SMSLA/GS/SOP/01	µg/L	BLQ(LOQ:0.01)	20.0 Max	No Relaxation
50	Aldrin	SMSLA/GS/SOP/01	µg/L	BLQ(LOQ:0.01)	0.03 Max	No Relaxation
51	Atrazine	SMSLA/GS/SOP/01	µg/L	BLQ(LOQ:0.01)	2.0 Max	No Relaxation
52	Butachlor	SMSLA/GS/SOP/01	µg/L	BLQ(LOQ:0.01)	125.0 Max	No Relaxation
53	Chlorpyrifos Ethyl	SMSLA/GS/SOP/01	µg/L	BLQ(LOQ:0.01)	30.0 Max	No Relaxation
54	Dieldrin	SMSLA/GS/SOP/01	µg/L	BLQ(LOQ:0.01)	0.03 Max	No relaxation
55	Endosulfan Sulfate	SMSLA/GS/SOP/01	µg/L	BLQ(LOQ:0.01)	0.4 Max	No Relaxation
56	Endosulfan-Alpha	SMSLA/GS/SOP/01	µg/L	BLQ(LOQ:0.01)	0.4 Max	No Relaxation
57	Endosulfan-Beta	SMSLA/GS/SOP/01	µg/L	BLQ(LOQ:0.01)	0.4 Max	No Relaxation
58	Ethion	SMSLA/GS/SOP/01	µg/L	BLQ(LOQ:0.01)	3.0 Max	No Relaxation

A. Manikandan
A. Manikandan
 Authorized Signatory - Chemical

Laboratory Address : 39/6, Thiruvallur High Road, Puduchatram Post, Thirumazhisai Via, Poonamallee Taluk, Chennai - 600124.
 Certified By : ISO 9001 & OHSAS 18001.

- ★ The results relate only to the items tested.
- ★ Reports shall not be reproduced except in full without the approval of the Laboratory.
- ★ The Laboratory's responsibility under this report is limited to proven willful negligence and will in no case be more than the invoiced amount. The Laboratory accepts no liability with regard to the origin or source from which the sample(s) is/are said to be extracted.



SMS LABS SERVICES PRIVATE LIMITED

TEST REPORT



Page 4 of 4

Report No : ENC-21080045-01

Report Date: 13 Aug 2021

S.NO	Parameter	Test Method	Unit	Results	Requirements as per IS 10500-2012-Amd : 3	
					Acceptable Limit	Permissible Limit in the absence of alternative source
59	HCH-Alpha	SMSLA/GS/SOP/01	µg/L	BLQ(LOQ:0.01)	0.01 Max	No Relaxation
60	HCH-Beta	SMSLA/GS/SOP/01	µg/L	BLQ(LOQ:0.01)	0.04 Max	No Relaxation
61	HCH-Delta	SMSLA/GS/SOP/01	µg/L	BLQ(LOQ:0.01)	0.04 Max	No Relaxation
62	HCH-Gamma	SMSLA/GS/SOP/01	µg/L	BLQ(LOQ:0.01)	2.0 Max	No Relaxation
63	Isoproturon	SMSLA/LS/SOP/01	µg/L	BLQ(LOQ:0.01)	9.0 Max	No Relaxation
64	Malathion	SMSLA/LS/SOP/01	µg/L	BLQ(LOQ:0.01)	190.0 Max	No Relaxation
65	Monocrotophos	SMSLA/LS/SOP/01	µg/L	BLQ(LOQ:0.01)	1.0 Max	No Relaxation
66	o,p-DDD	SMSLA/GS/SOP/01	µg/L	BLQ(LOQ:0.01)	1.0 Max	No Relaxation
67	o,p-DDE	SMSLA/GS/SOP/01	µg/L	BLQ(LOQ:0.01)	1.0 Max	No Relaxation
68	o,p-DDT	SMSLA/GS/SOP/01	µg/L	BLQ(LOQ:0.01)	1.0 Max	No Relaxation
69	p,p-DDD	SMSLA/GS/SOP/01	µg/L	BLQ(LOQ:0.01)	1.0 Max	No Relaxation
70	p,p-DDE	SMSLA/GS/SOP/01	µg/L	BLQ(LOQ:0.01)	1.0 Max	No Relaxation
71	p,p-DDT	SMSLA/GS/SOP/01	µg/L	BLQ(LOQ:0.01)	1.0 Max	No Relaxation
72	Parathion methyl	SMSLA/LS/SOP/01	µg/L	BLQ(LOQ:0.01)	0.3 Max	No Relaxation
73	Phorate	SMSLA/LS/SOP/01	µg/L	BLQ(LOQ:0.01)	2.0 Max	No Relaxation

Note : BLQ: Below Limit of Quantification LOQ: Limit of Quantification.
Free Residual Chlorine Limit to be applicable only Chlorinated Water.

Remarks : The Potable Raw Water sample conforms to the requirements of Acceptable Limits as per IS 10500:2012 : Amd : 3 for the Parameters tested above.

/***** End of the Report *****/

A. Manikandan
A. Manikandan
Authorized Signatory - Chemical

Laboratory Address : 39/6, Thiruvallur High Road, Puduchatram Post, Thirumazhisai Via, Poonamallee Taluk, Chennai - 600124.
Certified By : ISO 9001 & OHSAS 18001.

- ★ The results relate only to the items tested.
- ★ Reports shall not be reproduced except in full without the approval of the Laboratory.
- ★ The Laboratory's responsibility under this report is limited to proven willful negligence and will in no case be more than the invoiced amount. The Laboratory accepts no liability with regard to the origin or source from which the sample(s) is/are said to be extracted.



SMS LABS SERVICES PRIVATE LIMITED

TEST REPORT

Page 1 of 1

Report No : ENC-21080045-01

Report Date: 13 Aug 2021

Customer Name : M/s. A.R.Dairy Food Private Limited
Customer Address : No:10/5C, Madurai Road,Begampur Post, Dindigul-624002.
Sample Name : Water **Sample Quantity** : 15 Ltr
Sample Description : Potable Raw Water **Sample Received on** : 09 Aug 2021
Reference : Test Request Form Dated 07.08.2021 **Test Started on** : 09 Aug 2021
Sample Drawn By : Customer **Test Completed on** : 13 Aug 2021
Sample Location : UGR Main Tank A,B & C

TEST RESULTS

S.NO	Parameter	Test Method	Unit	Results	Requirements as per IS 10500-2012-Amd : 3	
					Acceptable Limit	Permissible Limit in the absence of alternative source
Clause 4, Table 4 Parameters Concerning Radioactive Substances						
1	Alpha Emitters*	IS 14194 (Part 02)	Bq/L	BLQ(MDA:0.0054)	0.1 Max	No Relaxation
2	Beta Emitters*	IS 14194 (Part 01)	Bq/L	BLQ(MDA:0.03)	1.0 Max	No Relaxation

Note : MDA: Minimum Detectable activity, BLQ: Below Limit of Quantification & Bq: Becquerel *Sub Contracted Parameters.

Remarks :The Potable Raw Water sample conforms to the requirements of Acceptable Limits as per IS 10500:2012 : Amd : 3 for the Parameters tested above.

/***** End of the Report *****/

M. Sarathkumar

M. Sarathkumar
Authorized Signatory - Chemical

Laboratory Address : 39/6, Thiruvallur High Road, Puduchatram Post, Thirumazhisai Via, Poonamallee Taluk, Chennai - 600124.
Certified By : ISO 9001 & OHSAS 18001.

- ★ The results relate only to the items tested.
- ★ Reports shall not be reproduced except in full without the approval of the Laboratory.
- ★ The Laboratory's responsibility under this report is limited to proven willful negligence and will in no case be more than the invoiced amount. The Laboratory accepts no liability with regard to the origin or source from which the sample(s) is/are said to be extracted.