

TEST REPORT



TC-6118

ULR - TC611823000024998F

Report No: QEN23070536-01

Page 1 of 4

Report Date: 03 Aug 2023

Customer Name

M/s. A.R.Dairy Food Private Limited

Customer Address

No:10/5C, Madurai Road, Begampur Post, Dindigul-624 002.

Sample Name

Sample Quantity

: 2 Ltr x 15No's

Sample Description

Potable Water

Sampling Date

: 27 Jul 2023

Reference

Test Request Form Dated 28.07.2023

Sample Received on

: 29 Jul 2023

Sample Drawn By

: Laboratory

Test Started on

: 29 Jul 2023

Sample Location

: UGR Main Tank "A" UGR Main Tank "B" & UGR Main Tank "C"

Test Completed on

: 03 Aug 2023

Sample Procedure

: SMSLA/EN/SOP/001, SMSLA/MB/SOP/06

TEST RESULTS

S.NO	Parameter	Test Method	Unit	Results	Requirements as per IS 10500-2012-Amd:4	
					Acceptable Limit	Permissible Limit in the absence of alternative source
Biolog	gical					
1	Escherichia coli	IS 15185	Per 100mL	Absent	Absent/100mL	Absent/100mL
2	Total Coliforms	IS 15185	Per 100mL	Absent	Absent/100mL	Absent/100mL
Claus	e 4, Table 1 Organoleptic And Phy	sical parameters		¥	•	9
3	Colour	IS 3025 (Part 04)	Hazen	Less than 1.0	5.0 Max	15.0 Max
4	Odour	IS 3025 (Part 05)		Agreeable	Agreeable	Agreeable
5	pH Value	IS 3025 (Part 11)		7.67	6.5 - 8.5	No Relaxation
6	Taste	IS 3025 (Part 08)		Agreeable	Agreeable	Agreeable
7	Total Dissolved Solids	IS 3025 (Part 16)	mg/L	740	500.0 Max	2000.0 Max
8	Turbidity	IS 3025 (Part 10)	NTU	Less than 0.1	1.0 Max	5.0 Max
Clause	e 4, Table 2 General Parameters C	oncerning Substances Unc	lesirable In E	xcessive Amounts	83 dr	
9	Aluminium	IS 3025 (Part 65)	mg/L	BLQ(LOQ:0.001)	0.03 Max	0.2 Max
10	Ammonia (as Total Ammonia-N)	IS 3025 (Part 34)	mg/L	BLQ(LOQ:0.03)	0.5 Max	No Relaxation
11	Anoinic Detergents (as MBAS)	Annex K of IS 13428	mg/L	BLQ(LOQ:0.05)	0.2 Max	1.0 Max
12	Barium	IS 3025 (Part 65)	mg/L	BLQ(LOQ:0.001)	0.7 Max	No Relaxation
13	Boron	IS 3025 (Part 65)	mg/L	BLQ(LOQ:0.025)	0.5 Max	2.4 Max

Microbiologist

Senior Chemist



TEST REPORT



TC-6118

ULR - TC611823000024998F

Report No: QEN23070536-01

Page 2 of 4

Report Date: 03 Aug 2023

S.NO	Parameter	Test Method	Unit	2 2	Requirements as per IS 10500-2012-Amd:4	
				Results	Acceptable Limit	Permissible Limiting in the absence of alternative source
14	Calcium (as Ca)	IS 3025 (Part 40)	mg/L	102	75.0 Max	200.0 Max
15	Chloramines (as Cl2)	APHA 23rd Edition:4500 Cl G 2017	mg/L	BLQ(LOQ:1.0)	4.0 Max	No Relaxation
16	Chloride (as Cl)	IS 3025 (Part 32)	mg/L	186	250.0 Max	1000.0 Max
17	Copper	IS 3025 (Part 65)	mg/L	BLQ(LOQ:0.001)	0.05 Max	1.5 Max
18	Fluoride as F	IS 3025 (Part 60)	mg/L	0.3	1.0 Max	1.5 Max
19	Free Residual Chlorine	IS 3025 (Part 26)	mg/L	BLQ(LOQ:0.1)	0.2 Min	1.0 Min
20	Iron (as Fe)	IS 3025 (Part 53)	mg/L	BLQ(LOQ:0.05)	1.0 Max	No Relaxation
21	Magnesium (as Mg)	IS 3025 (Part 46)	mg/L	29	30.0 Max	100.0 Max
22	Manganese	IS 3025 (Part 65)	mg/L	BLQ(LOQ:0.001)	0.1 Max	0.3 Max
23	Mineral Oil	IS 3025 (Part 39)	mg/L	BLQ(LOQ:1.0)	1.0 Max	No Relaxation
24	Nitrate (as NO3)	APHA 23rd Edition:4500 NO3 B 2017	mg/L	16	45.0 Max	No Relaxation
25	Phenolic Compound (as C6H5OH)	IS 3025 (Part 43) Sec 1	mg/L	BLQ(LOQ:0.001)	0.001 Max	0.002 Max
26	Selenium	IS 3025 (Part 65)	mg/L	BLQ(LOQ:0.001)	0.01 Max	No Relaxation
27	Silver	IS 3025 (Part 65)	mg/L	BLQ(LOQ:0.001)	0.1 Max	No Relaxation
28	Sulphate (as SO4)	IS 3025 (Part 24) Sec 1	mg/L	82	200.0 Max	400.0 Max
29	Sulphide (as H2S)	IS 3025 (Part 29)	mg/L	BLQ(LOQ:0.04)	0.05 Max	No Relaxation
30	Total Alkalinity (as CaCO3)	IS 3025 (Part 23)	mg/L	385	200.0 Max	600.0 Max
31	Total Hardness (as CaCO3)	IS 3025 (Part 21)	mg/L	375	200.0 Max	600.0 Max
32	Zinc	IS 3025 (Part 65)	mg/L	BLQ(LOQ:0.001)	5.0 Max	15.0 Max
Clause	e 4, Table 3 Parameters Concer	ning Toxic Substances				
33	Arsenic	IS 3025 (Part 65)	mg/L	BLQ(LOQ:0.001)	0.01 Max	No Relaxation
34	Bromo dichloromethane	SMSLA/GEF/SOP/03	mg/L	BLQ (LOQ:0.005)	0.06 Max	No relaxation
35	Bromoform	SMSLA/GEF/SOP/03	mg/L	BLQ (LOQ:0.005)	0.1 Max	No Relaxation
36	Cadmium	IS 3025 (Part 65)	mg/L	BLQ(LOQ:0.001)	0.003 Max	No Relaxation
37	Chloroform	SMSLA/GEF/SOP/03	mg/L	BLQ (LOQ:0.005)	0.2 Max	No Relaxation
38	Chromium	IS 3025 (Part 65)	mg/L	BLQ(LOQ:0.001)	0.05 Max	No Relaxation
39	Cyanide (as CN)	IS 3025 (Part 27)	mg/L	BLQ(LOQ:0.01)	0.05 Max	No Relaxation



R. PRABHU Senior Chemist



TEST REPORT




TC-6118

ULR - TC611823000024998F

Page 3 of 4 Report Date: 03 Aug 2023

Report No: QEN23070536-01

					Requirements as per IS 10500-2012-Amd:4	
S.NO	Parameter	Test Method	Unit	Results	Acceptable Limit	Permissible Limit in the absence of alternative source
40	Dibromochloromethane	SMSLA/GEF/SOP/03	mg/L	BLQ (LOQ:0.005)	0.1 Max	No Relaxation
41	Lead	IS 3025 (Part 65)	mg/L	BLQ(LOQ:0.001)	0.01 Max	No Relaxation
42	Mercury	EPA 200.8	mg/L	BLQ(LOQ:0.0005)	0.001 Max	No Relaxation
43	Molybdenum	IS 3025 (Part 65)	mg/L	BLQ(LOQ:0.001)	0.07 Max	No Relaxation
44	Nickel	IS 3025 (Part 65)	mg/L	BLQ(LOQ:0.001)	0.02 Max	No Relaxation
45	PAHs	SMSLA/GS/SOP/01	mg/L	BLQ(LOQ:0.00001) each	0.0001 Max	No Relaxation
46	PCBs	SMSLA/GS/SOP/01	mg/L	BLQ(LOQ:0.00001) each	0.0005 Max	No Relaxation
47	Uranium	IS 3025 (Part 65)	mg/L	BLQ(LOQ:0.001)	0.03 Max	No relaxation
Clause 4, Table 5 Pesticide Residues						
48	2,4-D	SMSLA/LS/SOP/01	μg/L	BLQ(LOQ:0.01)	30.0 Max	No Relaxation
49	Alachlor	SMSLA/GS/SOP/01	μg/L	BLQ(LOQ:0.01)	20.0 Max	No Relaxation
50	Aldrin	SMSLA/GS/SOP/01	μg/L	BLQ(LOQ:0.01)	0.03 Max	No Relaxation
51	Atrazine	SMSLA/GS/SOP/01	μg/L	BLQ(LOQ:0.01)	2.0 Max	No Relaxation
52	Butachlor	SMSLA/GS/SOP/01	μg/L	BLQ(LOQ:0.01)	125.0 Max	No Relaxation
53	Chlorpyrifos Ethyl	SMSLA/GS/SOP/01	μg/L	BLQ(LOQ:0.01)	30.0 Max	No Relaxation
54	Dieldrin	SMSLA/GS/SOP/01	μg/L	BLQ(LOQ:0.01)	0.03 Max	No relaxation
55	Endosulfan Sulfate	SMSLA/GS/SOP/01	μg/L	BLQ(LOQ:0.01)	0.4 Max	No Relaxation
56	Endosulfan-Alpha	SMSLA/GS/SOP/01	μg/L	BLQ(LOQ:0.01)	0.4 Max	No Relaxation
57	Endosulfan-Beta	SMSLA/GS/SOP/01	μg/L	BLQ(LOQ:0.01)	0.4 Max	No Relaxation
58	Ethion	SMSLA/GS/SOP/01	μg/L	BLQ(LOQ:0.01)	3.0 Max	No Relaxation
59	HCH-Alpha	SMSLA/GS/SOP/01	μg/L	BLQ(LOQ:0.01)	0.01 Max	No Relaxation
60	HCH-Beta	SMSLA/GS/SOP/01	μg/L	BLQ(LOQ:0.01)	0.04 Max	No Relaxation
61	HCH-Delta	SMSLA/GS/SOP/01	μg/L	BLQ(LOQ:0.01)	0.04 Max	No Relaxation
62	HCH-Gamma	SMSLA/GS/SOP/01	μg/L	BLQ(LOQ:0.01)	2.0 Max	No Relaxation
63	Isoproturon	SMSLA/LS/SOP/01	μg/L	BLQ(LOQ:0.01)	9.0 Max	No Relaxation
64	Malathion	SMSLA/LS/SOP/01	μg/L	BLQ(LOQ:0.01)	190.0 Max	No Relaxation
65	Monocrotophos	SMSLA/LS/SOP/01	μg/L	BLQ(LOQ:0.01)	1.0 Max	No Relaxation





TEST REPORT



TC-6118

ULR - TC611823000024998F

Report No: QEN23070536-01

Page 4 of 4

Report Date: 03 Aug 2023

	Parameter	Test Method	Unit	Results	Requirements as per IS 10500-2012-Amd:4	
S.NO					Acceptable Limit	Permissible Limit in the absence of alternative source
66	o,p-DDD	SMSLA/GS/SOP/01	μg/L	BLQ(LOQ:0.01)	1.0 Max	No Relaxation
67	o,p-DDE	SMSLA/GS/SOP/01	μg/L	BLQ(LOQ:0.01)	1.0 Max	No Relaxation
68	o,p-DDT	SMSLA/GS/SOP/01	μg/L	BLQ(LOQ:0.01)	1.0 Max	No Relaxation
69	p,p-DDD	SMSLA/GS/SOP/01	μg/L	BLQ(LOQ:0.01)	1.0 Max	No Relaxation
70	p,p-DDE	SMSLA/GS/SOP/01	μg/L	BLQ(LOQ:0.01)	1.0 Max	No Relaxation
71	p,p-DDT	SMSLA/GS/SOP/01	μg/L	BLQ(LOQ:0.01)	1.0 Max	No Relaxation
72	Parathion methyl ,	SMSLA/LS/SOP/01	μg/L	BLQ(LOQ:0.01)	0.3 Max	No Relaxation
73	Phorate	SMSLA/LS/SOP/01	μg/L	BLQ(LOQ:0.01)	2.0 Max	No Relaxation

lote : BLQ: Below Limit of Quantification LOQ: Limit of Quantification.

Free Residual Chlorine Limit to be applicable only for Chlorinated Water.

Remarks: The Potable Water Sample Conforms to the Requirements of Permissible Limits as per IS 10500:2012: Amd: 4

for the Parameters tested above.

/****** End of the Report ********/

K.PRAKASH Senior Chemist



TEST REPORT

Page 1 of 1

Report Date: 03 Aug 2023

Report No: QEN23070536-01

Customer Name

M/s. A.R.Dairy Food Private Limited

Customer Address

No:10/5C, Madurai Road, Begampur Post, Dindigul-624 002.

Sample Name

Sample Quantity

: 2 Ltr x 15No's

Sample Description

Potable Water

Sampling Date

: 27 Jul 2023

Reference

Test Request Form Dated 28.07.2023

Sample Received on

: 29 Jul 2023

Sample Drawn By

Test Started on

: 29 Jul 2023

Sample Location

Laboratory

UGR Main Tank "A"

Test Completed on

: 03 Aug 2023

Sample Procedure

SMSLA/EN/SOP/001

TEST RESULTS

s.no	Parameter	Test Method	Unit	Results	Requirements as per IS 10500-2012-Amd:4	
					Acceptable Limit	Permissible Limit in the absence of alternative source
Claus	e 4, Table 4 Parameters Concer	ning Radioactive Substances				
1	Alpha Emitters*	IS 14194 (Part 02)	Bq/L	BLQ(MDA:0.0054)	0.1 Max	No Relaxation
2	Beta Emitters*	IS 14194 (Part 01)	Bq/L	BLQ(MDA:0.03)	1.0 Max	No Relaxation

: MDA: Minimum Detectable activity, BLQ: Below Limit of Quantification & Bq: Becquerel *Sub Contracted Parameters.

Remarks: The Potable Water Sample Conforms to the requirements of Acceptable Limits as per IS 10500:2012: Amd: 4 for the Parameters tested above.

UGR Main Tank "B" & UGR Main Tank "C"

/****** End of the Report ********/

R. PRABHU

Laboratory Address: 39/6, Thiruvallur High Road, Puduchatram Post, Thirumazhisai Via, Poonamallee Taluk, Chennai - 600124.

Note: Test results relate only to the items tested. Test Report shall not be reproduced in full or part without the approval of SMS Labs. Non-Perishable remnant samples will be disposed 15 days from the date of receipt unless otherwise agreed with the customer except in case of regulatory samples, which will be retained for a specific period as per regulatory requirements; while perishable and environmental remnant samples will be disposed consequently upon completion of testing. Samples are not drawn by laboratory unless or otherwise stated. A satisfactory test report in no way implies that a product so tested is approved by NABL. The laboratory's responsibility under this report is limited to proven willful negligence and will in no case be more than the invoiced amount. The Laboratory accepts no liability with regard to the origin or source from which the sample(s) is/ are said to be extracted.



TEST REPORT

Page 1 of 1

Report Date: 03 Aug 2023

Report No: QEN23070536-01

Customer Name

: M/s. A.R.Dairy Food Private Limited

UGR Main Tank "B" & UGR Main Tank "C"

Customer Address

: No:10/5C, Madurai Road, Begampur Post, Dindigul-624 002.

Sample Name

Sample Quantity

: 2Ltr x 15No's

Sample Description

Sampling Date

: 28 Jul 2023

: Potable Water

: 29 Jul 2023

Reference

: Test Request Form Dated 28.07.2023

Sample Received on

Sample Drawn By

: Laboratory

Test Started on

: 29 Jul 2023

Sample Location

: UGR Main Tank "A"

Test Completed on

: 03 Aug 2023

Sample Procedure

: SMSLA/MB/SOP/06

TEST RESULTS

s.no	Parameter	Test Method	Unit	Results		
Proto	zoa			an e		
1	Algae & Toxin producing organisms	Microscopic Evaluation	-	Absent		
2	Cryptosporidium	SMSLA/MOLBIO/SOP/15		Not Detected		
3	Flagellates	Microscopic Evaluation		Absent		
4	Giardia	SMSLA/MOLBIO/SOP/16		Not Detected		
5	Zooplanktons	Microscopic Evaluation		Absent		
Virus						
6	MS2 Phage	SMSLA/MOLBIO/SOP/14		Not Detected		

/******* End of the Report ********/

Microbiologist