



SMS LABS SERVICES PRIVATE LIMITED



TEST REPORT

TC-6118

ULR - TC61182400009475F
Report No : QEN24020501-01

Page 1 of 4
Report Date : 27 Feb 2024

Customer Name : M/s. A.R.Dairy Food Private Limited
Customer Address : No:10/5C, Madurai Road, Begampur Post, Dindigul-624 002.
Sample Name : Potable Water
Sample Description : Potable Water
Reference : Customer Letter Dated 21.02.2024
Sample Drawn By : Laboratory
Sample Location : UGR Main Tank "A",
UGR Main Tank "B" & UGR Main Tank "C"
Sample Procedure : SMSLA/EN/SOP/001, SMSLA/MB/SOP/06

Sample Quantity : 2 Ltr x 15 No's
Sampling Date : 21 Feb 2024
Sample Received on : 22 Feb 2024
Test Started on : 22 Feb 2024
Test Completed on : 27 Feb 2024

TEST RESULTS

S.NO	Parameter	Test Method	Unit	Results	Requirements as per IS 10500-2012-Amd:4	
					Acceptable Limit	Permissible Limit in the absence of alternative source
Biological						
1	<i>Escherichia coli</i>	IS 15185	Per 100mL	Absent	Absent/100mL	Absent/100mL
2	<i>Total Coliforms</i>	IS 15185	Per 100mL	Absent	Absent/100mL	Absent/100mL
Clause 4, Table 1 Organoleptic And Physical parameters						
3	Colour	IS 3025 (Part 04)	Hzazen	Less than 1.0	5.0 Max	15.0 Max
4	Odour	IS 3025 (Part 05)	--	Agreeable	Agreeable	Agreeable
5	pH Value	IS 3025 (Part 11)	--	6.69	6.5 - 8.5	No Relaxation
6	Taste	IS 3025 (Part 08)	--	Agreeable	Agreeable	Agreeable
7	Total Dissolved Solids	IS 3025 (Part 16)	mg/L	34	500.0 Max	2000.0 Max
8	Turbidity	IS 3025 (Part 10)	NTU	Less than 0.1	1.0 Max	5.0 Max
Clause 4, Table 2 General Parameters Concerning Substances Undesirable In Excessive Amounts						
9	Aluminium	IS 3025 (Part 65)	mg/L	BLQ(LOQ:0.001)	0.03 Max	0.2 Max
10	Ammonia (as Total Ammonia-N)	IS 3025 (Part 34)	mg/L	BLQ(LOQ:0.03)	0.5 Max	No Relaxation
11	Anionic Detergents (as MBAS)	Annex K of IS 13428	mg/L	BLQ(LOQ:0.05)	0.2 Max	1.0 Max
12	Barium	IS 3025 (Part 65)	mg/L	BLQ(LOQ:0.001)	0.7 Max	No Relaxation
13	Boron	IS 3025 (Part 65)	mg/L	BLQ(LOQ:0.025)	0.5 Max	2.4 Max


J. Mohammed Shabir
Authorized Signatory-Biological


M. Sarathkumar
Authorized Signatory-Chemical

Laboratory Address: 39/6, Thiruvallur High Road, Puduchatram Post, Thirumazhisai Via, Poonamallee Taluk, Chennai - 600124.

Note: Test results relate only to the items tested. Test Report shall not be reproduced in full or part without the approval of SMS Labs. Non-Perishable remnant samples will be disposed 15 days from the date of receipt unless otherwise agreed with the customer except in case of regulatory samples, which will be retained for a specific period as per regulatory requirements; while perishable and environmental remnant samples will be disposed consequently upon completion of testing. Samples are not drawn by laboratory unless or otherwise stated. A satisfactory test report in no way implies that a product so tested is approved by NABL. The Laboratory accepts no liability with regard to the origin or source from which the sample(s) is/ are said to be extracted.



SMS LABS SERVICES PRIVATE LIMITED

TEST REPORT



TC-6118

ULR - TC611824000009475F
Report No : QEN24020501-01

Page 2 of 4
Report Date : 27 Feb 2024

S.NO	Parameter	Test Method	Unit	Results	Requirements as per IS 10500-2012-Amd:4	
					Acceptable Limit	Permissible Limit in the absence of alternative source
14	Calcium (as Ca)	IS 3025 (Part 40)	mg/L	3.2	75.0 Max	200.0 Max
15	Chloramines (as Cl2)	APHA 23rd Edition:4500 Cl G 2017	mg/L	BLQ(LOQ:1.0)	4.0 Max	No Relaxation
16	Chloride (as Cl)	IS 3025 (Part 32)	mg/L	9.5	250.0 Max	1000.0 Max
17	Copper	IS 3025 (Part 65)	mg/L	BLQ(LOQ:0.001)	0.05 Max	1.5 Max
18	Fluoride as F	IS 3025 (Part 60)	mg/L	BLQ(LOQ:0.1)	1.0 Max	1.5 Max
19	Free Residual Chlorine	IS 3025 (Part 26)	mg/L	BLQ(LOQ:0.1)	0.2 Min	1.0 Min
20	Iron (as Fe)	IS 3025 (Part 53)	mg/L	BLQ(LOQ:0.05)	1.0 Max	No Relaxation
21	Magnesium (as Mg)	IS 3025 (Part 46)	mg/L	1.2	30.0 Max	100.0 Max
22	Manganese	IS 3025 (Part 65)	mg/L	BLQ(LOQ:0.001)	0.1 Max	0.3 Max
23	Mineral Oil	IS 3025 (Part 39)	mg/L	BLQ(LOQ:1.0)	1.0 Max	No Relaxation
24	Nitrate (as NO3)	APHA 23rd Edition:4500 NO3 B 2017	mg/L	BLQ(LOQ:1.0)	45.0 Max	No Relaxation
25	Phenolic Compound (as C6H5OH)	IS 3025 (Part 43) Sec 1	mg/L	BLQ(LOQ:0.001)	0.001 Max	0.002 Max
26	Selenium	IS 3025 (Part 65)	mg/L	BLQ(LOQ:0.001)	0.01 Max	No Relaxation
27	Silver	IS 3025 (Part 65)	mg/L	BLQ(LOQ:0.001)	0.1 Max	No Relaxation
28	Sulphate (as SO4)	IS 3025 (Part 24) Sec 1	mg/L	3.6	200.0 Max	400.0 Max
29	Sulphide (as H2S)	IS 3025 (Part 29)	mg/L	BLQ(LOQ:0.04)	0.05 Max	No Relaxation
30	Total Alkalinity (as CaCO3)	IS 3025 (Part 23)	mg/L	16	200.0 Max	600.0 Max
31	Total Hardness (as CaCO3)	IS 3025 (Part 21)	mg/L	13	200.0 Max	600.0 Max
32	Zinc	IS 3025 (Part 65)	mg/L	BLQ(LOQ:0.001)	5.0 Max	15.0 Max
Clause 4, Table 3 Parameters Concerning Toxic Substances						
33	Arsenic	IS 3025 (Part 65)	mg/L	BLQ(LOQ:0.001)	0.01 Max	No Relaxation
34	Bromo dichloromethane	SMSLA/GEF/SOP/03	mg/L	BLQ (LOQ:0.005)	0.06 Max	No relaxation
35	Bromoform	SMSLA/GEF/SOP/03	mg/L	BLQ (LOQ:0.005)	0.1 Max	No Relaxation
36	Cadmium	IS 3025 (Part 65)	mg/L	BLQ(LOQ:0.001)	0.003 Max	No Relaxation
37	Chloroform	SMSLA/GEF/SOP/03	mg/L	BLQ (LOQ:0.005)	0.2 Max	No Relaxation
38	Chromium	IS 3025 (Part 65)	mg/L	BLQ(LOQ:0.001)	0.05 Max	No Relaxation
39	Cyanide (as CN)	IS 3025 (Part 27)	mg/L	BLQ(LOQ:0.01)	0.05 Max	No Relaxation

A. Kanagavel
Authorized Signatory-Chemical

M. Sarathkumar
Authorized Signatory-Chemical

Laboratory Address: 39/6, Thiruvallur High Road, Puduchatram Post, Thirumazhisai Via, Poonamallee Taluk, Chennai – 600124.

Note: Test results relate only to the items tested. Test Report shall not be reproduced in full or part without the approval of SMS Labs. Non-Perishable remnant samples will be disposed 15 days from the date of receipt unless otherwise agreed with the customer except in case of regulatory samples, which will be retained for a specific period as per regulatory requirements; while perishable and environmental remnant samples will be disposed consequently upon completion of testing. Samples are not drawn by laboratory unless or otherwise stated. A satisfactory test report in no way implies that a product so tested is approved by NABL. The Laboratory accepts no liability with regard to the origin or source from which the sample(s) is/ are said to be extracted.



TEST REPORT

TC-6118

ULR - TC611824000009475F
Report No : QEN24020501-01

Page 3 of 4
Report Date : 27 Feb 2024

S.NO	Parameter	Test Method	Unit	Results	Requirements as per IS 10500-2012-Amd:4	
					Acceptable Limit	Permissible Limit in the absence of alternative source
40	Dibromochloromethane	SMSLA/GEF/SOP/03	mg/L	BLQ (LOQ:0.005)	0.1 Max	No Relaxation
41	Lead	IS 3025 (Part 65)	mg/L	BLQ(LOQ:0.001)	0.01 Max	No Relaxation
42	Mercury	EPA 200.8	mg/L	BLQ(LOQ:0.0005)	0.001 Max	No Relaxation
43	Molybdenum	IS 3025 (Part 65)	mg/L	BLQ(LOQ:0.001)	0.07 Max	No Relaxation
44	Nickel	IS 3025 (Part 65)	mg/L	BLQ(LOQ:0.001)	0.02 Max	No Relaxation
45	PAHs	SMSLA/GS/SOP/01	mg/L	BLQ(LOQ:0.00001) each	0.0001 Max	No Relaxation
46	PCBs	SMSLA/GS/SOP/01	mg/L	BLQ(LOQ:0.00001) each	0.0005 Max	No Relaxation
47	Uranium	IS 3025 (Part 65)	mg/L	BLQ(LOQ:0.001)	0.03 Max	No relaxation
Clause 4, Table 5 Pesticide Residues						
48	2,4-D	SMSLA/L.S/SOP/01	µg/L	BLQ(LOQ:0.01)	30.0 Max	No Relaxation
49	Alachlor	SMSLA/GS/SOP/01	µg/L	BLQ(LOQ:0.01)	20.0 Max	No Relaxation
50	Aldrin	SMSLA/GS/SOP/01	µg/L	BLQ(LOQ:0.01)	0.03 Max	No Relaxation
51	Atrazine	SMSLA/GS/SOP/01	µg/L	BLQ(LOQ:0.01)	2.0 Max	No Relaxation
52	Butachlor	SMSLA/GS/SOP/01	µg/L	BLQ(LOQ:0.01)	125.0 Max	No Relaxation
53	Chlorpyrifos Ethyl	SMSLA/GS/SOP/01	µg/L	BLQ(LOQ:0.01)	30.0 Max	No Relaxation
54	Dieldrin	SMSLA/GS/SOP/01	µg/L	BLQ(LOQ:0.01)	0.03 Max	No relaxation
55	Endosulfan Sulfate	SMSLA/GS/SOP/01	µg/L	BLQ(LOQ:0.01)	0.4 Max	No Relaxation
56	Endosulfan-Alpha	SMSLA/GS/SOP/01	µg/L	BLQ(LOQ:0.01)		No Relaxation
57	Endosulfan-Beta	SMSLA/GS/SOP/01	µg/L	BLQ(LOQ:0.01)		No Relaxation
58	Ethion	SMSLA/GS/SOP/01	µg/L	BLQ(LOQ:0.01)	3.0 Max	No Relaxation
59	HCH-Alpha	SMSLA/GS/SOP/01	µg/L	BLQ(LOQ:0.01)	0.01 Max	No Relaxation
60	HCH-Beta	SMSLA/GS/SOP/01	µg/L	BLQ(LOQ:0.01)	0.04 Max	No Relaxation
61	HCH-Delta	SMSLA/GS/SOP/01	µg/L	BLQ(LOQ:0.01)	0.04 Max	No Relaxation
62	HCH-Gamma	SMSLA/GS/SOP/01	µg/L	BLQ(LOQ:0.01)	2.0 Max	No Relaxation
63	Isoproturon	SMSLA/L.S/SOP/01	µg/L	BLQ(LOQ:0.01)	9.0 Max	No Relaxation
64	Malathion	SMSLA/L.S/SOP/01	µg/L	BLQ(LOQ:0.01)	190.0 Max	No Relaxation
65	Monocrotophos	SMSLA/L.S/SOP/01	µg/L	BLQ(LOQ:0.01)	1.0 Max	No Relaxation


A. K. Rangavel
Authorized Signatory-Chemical

Laboratory Address: 39/6, Thiruvallur High Road, Puduchatram Post, Thirumazhisai Via, Poonamallee Taluk, Chennai – 600124.

Note: Test results relate only to the items tested. Test Report shall not be reproduced in full or part without the approval of SMS Labs. Non-Perishable remnant samples will be disposed 15 days from the date of receipt unless otherwise agreed with the customer except in case of regulatory samples, which will be retained for a specific period as per regulatory requirements; while perishable and environmental remnant samples will be disposed consequently upon completion of testing. Samples are not drawn by laboratory unless or otherwise stated. A satisfactory test report in no way implies that a product so tested is approved by NABL. The Laboratory accepts no liability with regard to the origin or source from which the sample(s) is/ are said to be extracted.



SMS LABS SERVICES PRIVATE LIMITED



TEST REPORT

TC-6118

ULR - TC61182400009475F
Report No : QEN24020501-01

Page 4 of 4
Report Date : 27 Feb 2024

S.NO	Parameter	Test Method	Unit	Results	Requirements as per IS 10500-2012-Amd:4	
					Acceptable Limit	Permissible Limit in the absence of alternative source
66	o,p-DDD	SMSLA/GS/SOP/01	µg/L	BL.Q(LOQ:0.01)	1.0 Max	No Relaxation
67	o,p-DDE	SMSLA/GS/SOP/01	µg/L	BL.Q(LOQ:0.01)		No Relaxation
68	o,p-DDT	SMSLA/GS/SOP/01	µg/L	BL.Q(LOQ:0.01)		No Relaxation
69	p,p-DDD	SMSLA/GS/SOP/01	µg/L	BL.Q(LOQ:0.01)		No Relaxation
70	p,p-DDE	SMSLA/GS/SOP/01	µg/L	BL.Q(LOQ:0.01)		No Relaxation
71	p,p-DDT	SMSLA/GS/SOP/01	µg/L	BL.Q(LOQ:0.01)		No Relaxation
72	Parathion methyl	SMSLA/LS/SOP/01	µg/L	BL.Q(LOQ:0.01)	0.3 Max	No Relaxation
73	Phorate	SMSLA/LS/SOP/01	µg/L	BL.Q(LOQ:0.01)	2.0 Max	No Relaxation

Note : BLQ: Below Limit of Quantification LOQ: Limit of Quantification.
Free Residual Chlorine Limit to be applicable only Chlorinated Water.

Remarks : The Potable Water Sample Conforms to the Requirements of Acceptable Limits as per IS 10500:2012 : Amd : 4 for the Parameters tested above.

/***** End of the Report *****/


A. Kanagavel
Authorized Signatory-Chemical

Laboratory Address: 39/6, Thiruvallur High Road, Puduchatram Post, Thirumazhisai Via, Poonamallee Taluk, Chennai – 600124.

Note: Test results relate only to the items tested. Test Report shall not be reproduced in full or part without the approval of SMS Labs. Non-Perishable remnant samples will be disposed 15 days from the date of receipt unless otherwise agreed with the customer except in case of regulatory samples, which will be retained for a specific period as per regulatory requirements; while perishable and environmental remnant samples will be disposed consequently upon completion of testing. Samples are not drawn by laboratory unless or otherwise stated. A satisfactory test report in no way implies that a product so tested is approved by NABL. The Laboratory accepts no liability with regard to the origin or source from which the sample(s) is/ are said to be extracted.



SMS LABS SERVICES PRIVATE LIMITED

TEST REPORT

Page 1 of 1

Report No : QEN24020501-01

Report Date : 27 Feb 2024

Customer Name : M/s. A.R.Dairy Food Private Limited
Customer Address : No:10/5C, Madurai Road,Begampur Post, Dindigul-624 002.
Sample Name : Potable Water **Sample Quantity** : 2 Ltr x 15 No's
Sample Description : Potable Water **Sampling Date** : 21 Feb 2024
Reference : Customer Letter Dated 21.02.2024 **Sample Received on** : 22 Feb 2024
Sample Drawn By : Laboratory **Test Started on** : 22 Feb 2024
Sample Location : UGR Main Tank "A",
UGR Main Tank "B" & UGR Main Tank "C" **Test Completed on** : 27 Feb 2024
Sample Procedure : SMSLA/EN/SOP/001

TEST RESULTS

S.NO	Parameter	Test Method	Unit	Results	Requirements as per IS 10500-2012-Amd:4	
					Acceptable Limit	Permissible Limit in the absence of alternative source
Clause 4, Table 4 Parameters Concerning Radioactive Substances						
1	Alpha Emitters*	IS 14194 (Part 02)	Bq/L	BLQ(MDA:0.0054)	0.1 Max	No Relaxation
2	Beta Emitters*	IS 14194 (Part 01)	Bq/L	BLQ(MDA:0.02)	1.0 Max	No Relaxation

Note : MDA: Minimum Detectable activity, BLQ: Below Limit of Quantification & Bq: Becquerel *Sub Contracted Parameters.

Remarks :The Potable Water sample conforms to the requirements of Acceptable Limits as per IS 10500:2012 : Amd : 4 for the Parameters tested above

/***** End of the Report *****/


M. Sarathkumar
Authorized Signatory-Chemical

Laboratory Address: 39/6, Thiruvallur High Road, Puduchatram Post, Thirumazhisai Via, Poonamallee Taluk, Chennai – 600124.

Note: Test results relate only to the items tested. Test Report shall not be reproduced in full or part without the approval of SMS Labs. Non-Perishable remnant samples will be disposed 15 days from the date of receipt unless otherwise agreed with the customer except in case of regulatory samples, which will be retained for a specific period as per regulatory requirements; while perishable and environmental remnant samples will be disposed consequently upon completion of testing. Samples are not drawn by laboratory unless or otherwise stated. A satisfactory test report in no way implies that a product so tested is approved by NABL. The Laboratory accepts no liability with regard to the origin or source from which the sample(s) is/ are said to be extracted.



SMS LABS SERVICES PRIVATE LIMITED

TEST REPORT

Page 1 of 1

Report No : QEN24020501-01

Report Date : 27 Feb 2024

Customer Name : M/s. A.R.Dairy Food Private Limited
Customer Address : No:10/5C, Madurai Road,Begampur Post, Dindigul-624 002.
Sample Name : Potable Water **Sample Quantity** : 2 Ltr x 15 No's
Sample Description : Potable Water **Sampling Date** : 21 Feb 2024
Reference : Customer Letter Dated 21.02.2024 **Sample Received on** : 22 Feb 2024
Sample Drawn By : Laboratory **Test Started on** : 22 Feb 2024
Sample Location : UGR Main Tank "A",
UGR Main Tank "B" & UGR Main Tank "C" **Test Completed on** : 27 Feb 2024
Sample Procedure : SMSLA/MB/SOP/06

TEST RESULTS

S.NO	Parameter	Test Method	Unit	Results
Protozoa				
1	Algae & Toxin producing organisms	Microscopic Evaluation	--	Absent
2	Cryptosporidium	SMSLA/MOL.BIO/SOP/11	--	Not Detected
3	Flagellates	Microscopic Evaluation	--	Absent
4	Giardia	SMSLA/MOL.BIO/SOP/12	--	Not Detected
5	Zooplanktons	Microscopic Evaluation	--	Absent
Virus				
6	MS2 Phage	SMSLA/MOL.BIO/SOP/10	--	Not Detected

/***** End of the Report *****/


J.Mohammed Shabir
Authorized Signatory-Biological

Laboratory Address: 39/6, Thiruvallur High Road, Puduchatram Post, Thirumazhisai Via, Poonamallee Taluk, Chennai – 600124.

Note: Test results relate only to the items tested. Test Report shall not be reproduced in full or part without the approval of SMS Labs. Non-Perishable remnant samples will be disposed 15 days from the date of receipt unless otherwise agreed with the customer except in case of regulatory samples, which will be retained for a specific period as per regulatory requirements; while perishable and environmental remnant samples will be disposed consequently upon completion of testing. Samples are not drawn by laboratory unless or otherwise stated. A satisfactory test report in no way implies that a product so tested is approved by NABL. The Laboratory accepts no liability with regard to the origin or source from which the sample(s) is/ are said to be extracted.